



Global grid

Elia grid
Impact of renewable energies
Global grid
Energy future

Contents

Medium-Term / Short Term / Real-time management of the grid

Overhead lines <> Underground cables

Import/export capacities / Market coupling

Impact of renewable energies on grid management

Wind power zone V^3 and uncoupling

PV: disconnection at 50.2 Hz + responsive control


Environmental objectives

Global grid

Energy future


Le Groupe Elia

Le groupe Elia, une position unique au coeur de l'Europe



Le groupe Elia s'articule autour de 2 gestionnaires de réseau de transport haute tension (GRT),
Elia en Belgique,
50Hertz en Allemagne

Role of ELIA



The TSO is a vital link between the production and the industrial or private consumers

Elia in some numbers



800

high voltage
substations



30.000
-
380.000



22.000
pylons




5.560

km overhead
lines




2.800

km underground
cables



81,7 TWh



Elia is de Belgian Transmission System Operator
(30 kV - 380 kV) managing over 8.400 km
lines and underground cables.

Medium-Term / Short-Term / Real-Time management of the grid



Permanent monitoring of all equipment



Any component, even the largest (1,000 MW power plant, international line), can be tripped

- *Always check that the N-1 is covered. If NOK, look for a solution as quickly as possible.*



Importance of preparation outage planning and control reserve volumes (Prim R, Sec R, Tert R)

Main controls

- **N-1 rule respected**
- **Primary reserve (R1):** 3000 MW in ENTSO-E. Enough for facing the loss of 2 of the biggest nuclear plants within 15' Frequency deviations and involuntary power exchanges on borders occur
- **Secondary reserve (automatic):** Used in order to restore the initial balance between generation and consumption and thus restore frequency and cross border power exchanges.
- **Tertiary reserve (manuel):** In case of larger imbalances in the control area.


Process schedule

The process is iterative and each day is analysed at least seven times.

The closer day D, the more accurate the data and hypotheses.




Day Ahead Congestion Forecast: 25 countries



N-1 concept


Example 1



N-1 NOK

N-1 concept

Example 2



N-1 OK

Italy, black-out on 28 September 2003

N-1 rule not respected



Overhead lines <> Underground cables

Heating of electrical connections

- cooling underground cables is more difficult than cooling overhead lines



Larger cable section for the same current to limit heating.

Capacitive generation for lines & cables

$$\omega C U^2$$

Voltage	Line capacitive generation	Cable capacitive generation
380 kV	± 0,55 Mvar/km	± 20 Mvar/km
220 kv	± 0,15 Mvar/km	± 7,5 Mvar/km
150 kV	± 0,06 Mvar/km	± 3,5 Mvar/km

Impact reactive power on voltage

Impact energizing circuit (line/cable) on voltage

S_{CC} (short circuit power)


$$\Delta U(p.u.) \approx \frac{\text{reactive generation circuit (rgc)}}{S_{CC}}$$

Ferranti effect for circuit (line/cable)


$|U|$ = substation voltage before energizing circuit

$$|U_1| \approx |U| + \frac{rgc}{S_{CC}} \quad \text{after energizing circuit}$$

$$|U_2| \approx |U| + \frac{rgc}{S_{CC}} + \frac{rgc}{2} X$$




Ferranti effect for circuit (line/cable)



$|U|$ = substation voltage before energizing circuit

	$ U $	$ U1 $	$ U2 $
line (100 km)	380 kV	$ U + 0,2\%$	$ U + 0,8\%$
cable (100 km)	380 kV	$ U + 8\%$	$ U + 20\%$

Connection 380 kV : « Boucle du Hainaut »



Import/export capacities / Market coupling

Import/export capacities




Import/export generates Loop flows

Potential import/export capacities

Problem of loop flows

Controlling loop flows
Electricity follows the laws of physics:
path of least resistance



Impact of wind generation in Germany on the Elia grid

- Unscheduled flows:
 - Caused by wind farms located in neighbouring countries (north of Germany)
 - Variations between -2,000 and 2,000 MW on the Belgian grid




Figure 13: Main corridors of electrical power transmission in the Base Case





Figure 14: Changes of electrical power transmission in UCTE Scenario North

Flow management



Installation of Phase Shifter Transformers on the Northern border for managing increasing Loop flows

Coreso: centralised coordination between TSOs


- The first Regional Technical Coordination Service Centre
- Independent company (SA) with its own employees
- Created December 2008 in Brussels
- Operational since 16 February 7d/7 (afternoon shift)
- Round-the-clock operations since 29 June 2009
- Employs 25 engineers (18 are on shift)





Impact of import/export capacities on the markets

Market Coupling

Market Coupling




Market Coupling (basic concept)




- Isolated price Market A < isolated Price Market B
- Market A can export to market B (purchase- and sale curve shift)

Market Coupling (basic concept)



- Isolated price Market A < isolated Price Market B
- Market A can export to market B (purchase- and sale curve shift)

Market Coupling (basic concept)



- Isolated price Market A < isolated Price Market B
- Market A can export to market B (purchase- and sale curve shift)
- Prices market A and B converge till price market A = price market B

Impact of renewable energies on grid management


Germany, incident on 4 Novembre 2006

Le Norwegian Pearl





Incident on 4 November 2006

- Area 1 under-frequency
- Area 2 over-frequency
- Area 3 under-frequency



Incident on 4 November 2006

Europe is divided into 3 electric zones



Impact of decentralised generation on GRT activities

- Although decentralised generation units are connected to DSOs' grids, as the volume of these units is growing significantly, it affects the overall management of the electricity grid in Belgium.

1. Management of the electricity grid in Belgium


1. Balance between generation \leftrightarrow load
2. Management of system services: Prim R, Sec R, Tert R, voltage control
3. Management of flows, import/export, Must Run
4. System security, safeguard plan

Grid stability

The increase in power electronic based energy feed-in impacts grid stability which is mainly ensured by synchronous generators today.


Management of the electricity grid

- **Balance between generation \leftrightarrow consumption**
- AC electricity is not stored, generation and consumption must always be balanced




* Source: Elia Communication

Impact of forecasting errors




Delta P = 1211 MW
 (=43% of $P_{\text{installed}}$)

Belgian Wind-Power Forecasting




Delta P = 729 MW
 (=41% of $P_{\text{installed}}$)

Impact on CWE merit order



CWE Prices 20/11/2016



New needs to be taken into account

➤ **Balance between generation \leftrightarrow load**

- Good overview of decentralised generation units per domain of activity and substation
- Wind/solar/temperature forecasting tools
- System service management: takes into account the intermittent nature of renewable energies as regards the volume of reserves
 - ✓ Prim R, Sec R, Tert R

Wind Forecasting

Weekly Belgian Wind-Power Forecasting




— Measured & Upscaled
— Most recent forecast

-- Most recent forecast P10
-- Most recent forecast P90

Solar Forecasting

Solar-PV Power Forecasting for Belgium



— Measured & Upscaled
— Intraday forecast
— Day-ahead Forecast

-- Forecast P10
-- Forecast P90

Wind power

Available theoretical power

The available wind power P_{vent} is equal to:

$$P_{\text{vent}} = \frac{1}{2} \rho A \cdot v_{\text{vent}}^3 \quad [\text{W}]$$

- ρ = Air density (kg/m^3)
- A = Area swept by the blades (m^2)
- v_{vent} = Wind speed [m/s]

Example :


Wind speed: 10 m/s, Rotor diameter: 82 m

Wind power: $1/2 \times 1,225 \times 5.281 \times 10^3 = 3.235 \times 10^3 \text{ W}$ ou 3.235 kW


Captured power by the wind turbine = Wind power x **cp**

Cp : performance coefficient, theoretical maximum = 0,59

Power curve= f(wind speed)




Restrictive areas in wind turbine operation



Onshore farms

Monthly generation of a farm



Onshore farm


Monthly monotonic curve for the same farm



2. Underfrequency:

Optional active power boost, using the inertia of the rotor.


- ✓ $P_{\text{boost}} = 10\%P_{\text{rated}}$
- ✓ Available as soon as $P_{\text{actual}} \geq 4\%P_{\text{rated}}$
- ✓ P_{boost} fully available within 800ms
- ✓ Boost for max. 10 seconds
- ✓ Recovery time after boost = $2 \times T_{\text{boost}}$




- Performance achieved by changing excitation, using rotor inertia.
- Activated based on local frequency measurement.
- Additional investment in WF necessary.
- Cost relevant => Economical value for the power system?
- Impact to the max. installable wind power?

Photovoltaic

Potential in Europe




Yearly total of global irradiation on horizontal surface



Risk of disconnection at 50.2 Hz


DE, BE, FR, AT = **15,000 MWp**
 VDE 0126 standard
 Tripping at 50.2 Hz



→ Risk of increasing uncontrolled frequency fluctuations
 taking into account the f-sensitivity of generation (primary reserve + self-regulation) and load

Modification of the standard: gradual reduction of generation

- New units (from 2012 onwards)
 - Gradual reduction of generation
- Existing units
 - Coordinated retrofitting





Voltage problems

Standard DIN VDE 0126-1-1

- Maximum instantaneous voltage: **264.5 V** (115%)
- Maximum average voltage over 10 minutes: **253.0 V** (110%)
- Former instantaneous limit: **243.8 V** (106%)
- Reconnection after **30 seconds**

Consequences at low voltage



PV Germany: SMA solution





Fig. 4: Among others, the reactive power may be regulated as a function of the supplied active power

Environmental Objectives

European Objectives

	2008-2012	2020	2030	2050
Europe	GES : - 8%/1990	GES : -20% /1990	GES : - 40%/1990 = -43%/2005 (ETS) Et -30%/2005 (non-ETS)	GES :- 80 à - 95% /1990
		EnR : 20% consommation finale brute d'énergie	EnR : 32% consommation finale brute d'énergie	
		EE : -20% consommation énergie primaire	EE : 32.5% d'efficacité énergétique (consommation primaire et/ou finale)	

European Objectives 2040-2050




Source: [EUC-6]

The total energy consumed will be reduced with additional energy efficiency measures

The electricity share in the final energy consumption will increase with additional electrification

The increase of renewables in the energy mix and particularly in the electricity sector will increase

Belgian Objectives 2030 (Walloon region)



WEM : With Existing Measures

WAM : With Additional Measures

Belgian Objectives 2030 (Walloon region)




Figure 39 : Evolution de l'énergie renouvelable en Wallonie


Belgian Objectives 2030 (Walloon region)

Consommation finale (GWh)	2005	2030 WEM	2020 WAM	2030 WAM	Ecart 2030 WAM-WEM	Ecart 30-05 WAM %	Ecart 30-20 WAM %
Résidentiel	37 585	30 018	29 524	26 141	-12.92%	-30.45%	-11.46%
Tertiaire	12 249	13 800	12 813	12 146	-11.99%	-0.84%	-5.21%
Industrie	61 793	41 375	39 408	40 272	-2.67%	-34.83%	2.19%
Agriculture	1 289	1 289	1 289	1 289	0.00%	0.00%	0.00%
Transport	36 305	43 916	35 265	35 619	-18.89%	-1.89%	1%
TOTAL Consommation finale énergétique	149 221	130 398	118 300	115 467	-11.45%	-22.62%	-2.39%


Tableau 12 : Consommation finale WAM

Renewable Energy in Germany (during one week)


- **WIND**



- **SOLAR**



2040, need storage and flexible demand during periods with no wind and no sun



Hydraulic storage

Exemple :

available power and energy from a waterfall


Types of storage

- Hydraulic : pumped storage
- Lithium ion batteries
- Biomass
- Power to Gas : H₂ or CH₄
- CAES (compressed air energy storage)
- Kinetic energy
- Sensitive or latent heat
- Etc.

Types of storage and potential

SIEMENS

Ragone Diagram



Hydrogen can be stored cost-effectively and in large scale.

Hydrogen production

Silyzer 300

Large scale PEM electrolyzer

SIEMENS

17.5 MW

per full module array
(24 modules)

75%


System efficiency
(higher heating value)

24 modules

to build a
module array

340 kg

hydrogen per hour
per module array
(24 modules)




Silyzer 300 – module array
(24 modules)


H2 to electricity

Power to Gas (Hydrogen), how it looks like
 Reconversion of H2 to electricity & heat, kW to MW

SIEMENS




Fuel Cell
 kW – MW, $\eta \approx 58\%$



		Cyl	Displac	Power (kW)
SFGLD	240	8L	24	250
SFGLD	480	16V	48	500


Gas Motor
 kW – MW, $\eta \approx 35\%$



Gas Turbine
 25 – 50 MW, $\eta \approx 35\% - 57\%$


Methanol production

	Net heating value (kWh/l)
Diesel fuel	9,96
Methanol	4,37



Global Grid

Global Grid



Technical characteristics of the global grid

Need:


Transport of very large power over long distances

Adapted technology:

Direct current links


- Low losses
- Easy flow modulation
- Participation in system services

Nemo Link :new electricity interconnector between UK and the continent




The ALEGrO interconnector

Converter station technology	HVDC VSC multilevel Symmetrical Monopole	
Bi-directional capacity	~ 1000 MW	
Cable technology	HVDC XLPE	
Applied DC voltage	320 kV	
New interconnection	Belgium	Germany
TSO	Elia	Amprion
Region	Liège	Aachen
Converter station location	Visé	Oberzier
Route length	49 km	45 km



Energy future

Energy future



Energy future

Technical problem

- Intermittence of renewable energies
- Variability of renewable energies



Problems to be solved locally with storage, micro grid, DSM, and at European and Global level with global grid

Political issue

- Nuclear shutdown
- Réduction of CO2 emissions

Global problem to solve at planet level

Energy future



Samuele Furfari

Data : BP 2016

Many thanks for your attention!

Jean-Jacques Lambin

ELIA SYSTEM OPERATOR
Boulevard de l'Empereur 20
1000 Brussels

+32 2 546 70 11
info@elia.be

www.elia.be
An Elia Group company

Brussels, 2 December, 2021